



*An Online PDH Course
brought to you by
CEDengineering.com*

Foreign Voltages and Frequency Guide

Course No: E03-022
Credit: 3 PDH

Jeffery Cwalinski, P. E.



Continuing Education and Development, Inc.

P: (877) 322-5800
info@cedengineering.com

This course was adapted from “United Facilities Criteria, UFC 3-510-01”, document titled “Technical Manual TM 5-688, Foreign Voltages and frequencies Guide”, which is in the public domain.

TECHNICAL MANUAL }
 No. 5-688

HEADQUARTERS
 DEPARTMENT OF THE ARMY
 Washington, DC, 12 November 1999

Approved for public release; distribution is unlimited.

FOREIGN VOLTAGES AND FREQUENCIES GUIDE

| | <u>Paragraph</u> | <u>Page</u> |
|---|------------------|-------------|
| Chapter 1. INTRODUCTION | | |
| Purpose | 1-1 | 1-1 |
| Scope | 1-2 | 1-1 |
| References | 1-3 | 1-1 |
| Chapter 2. EQUIPMENT SENSITIVE TO FREQUENCY AND VOLTAGE LEVELS | | |
| Theoretical overview | 2-1 | 2-1 |
| Heating, ventilating, and air conditioning (HVAC) | 2-2 | 2-3 |
| Electrical distribution and protection | 2-3 | 2-3 |
| Medium voltage distribution equipment: 50 Hz 60 Hz | 2-4 | 2-4 |
| Safety and security equipment | 2-5 | 2-5 |
| Communication equipment | 2-6 | 2-5 |
| Lighting | 2-7 | 2-5 |
| Other electrical equipment | 2-8 | 2-6 |
| Chapter 3. EQUIPMENT DERATING | | |
| Derating under 50 Hz conditions | 3-1 | 3-1 |
| Heating, ventilating, and air conditioning (HVAC) for derating | 3-2 | 3-1 |
| Electrical distribution and protection | 3-3 | 3-1 |
| Safety and security equipment for derating | 3-4 | 3-2 |
| Communication equipment for derating | 3-5 | 3-2 |
| Lighting for derating | 3-6 | 3-2 |
| Other electrical equipment for derating | 3-7 | 3-2 |
| Derating under alternate voltage conditions | 3-8 | 3-2 |
| Recommendations | 3-9 | 3-3 |
| Summary | 3-10 | 3-3 |
| Appendix A. REFERENCES | | A-1 |
| Appendix B. FREQUENCY AND SINGLE- AND THREE-PHASE VOLTAGE LEVELS BY COUNTRY | | B-1 |
| Appendix C. DERATING FACTORS | | C-1 |

LIST OF FIGURES

| <u>Number</u> | <u>Page</u> |
|--|-------------|
| 2-1. Simplified two-winding transformer | 2-1 |
| 2-2. Magnetization curve for the transformer's iron core | 2-2 |

LIST OF TABLE

| <u>Number</u> | <u>Page</u> |
|---|-------------|
| B-1. Frequency and single and three-phase voltage levels by country | B-1 |

CHAPTER 1

INTRODUCTION

1-1. Purpose.

This manual provides guidance required to identify the voltage and frequency standards of various foreign countries for both medium and low voltage systems. It also identifies the classes of equipment that are sensitive to voltage and frequency differences. Foreign countries around the world use different electrical standards for voltage and frequency than those of the United States. Some electrical equipment will operate properly at an electrical frequency of either 50 or 60 Hz. Equipment designed for 60 Hz that will not operate properly at 50 Hz is termed "50 Hz sensitive," and equipment designed for 50 Hz that will not operate properly at 60 Hz is termed "60 Hz sensitive."

1-2. Scope.

This manual identifies the classes of electrical equipment that are sensitive to frequency and voltage variations. Appendix B covers identification of various low and medium voltage levels, along with the system frequencies, used by countries around the world. Derating factors are discussed and developed for the six generic types of equipment in chapter 3. Appendix C summarizes the derating factors presented in chapter 3 for different voltage and frequency environments.

1-3. References.

Appendix A contains a list of publications referenced in this manual.

CHAPTER 2

EQUIPMENT SENSITIVE TO FREQUENCY AND VOLTAGE LEVELS

2-1. Theoretical overview.

Equipment sensitive to frequency and or voltage is designed to operate within certain tolerances. Most equipment is sensitive to large changes in the supply voltage level because more current will flow through a device when the voltage level of the supply is increased (the current through the device is equal to the voltage across the device divided by the impedance of the device). When a larger current flows, the heat dissipated in the device increases (the heat dissipated by the device is proportional to the square of the current). Thus, doubling the voltage will typically double the current, resulting in the device dissipating four times the heat. Most devices cannot tolerate this amount of heat and cannot operate reliably with a supply voltage level more than 10 percent or so higher than their rated voltage.

a. An additional complication arises in the case of devices that use magnetic coupling. Since most electrical equipment depends on a magnetic field as the medium for transferring and converting energy, the following paragraphs discuss a basic transformer to explain how the magnetic circuit depends on the frequency and amplitude of the applied voltage.

b. A transformer enables electrical energy to be transferred with high efficiency from one voltage level to another at the same frequency. Consider a simplified view of a transformer with a sinusoidal voltage source, v , applied to the primary circuit and the secondary circuit open, as shown in figure 2-1. The operation of the

transformer depends on several natural laws including the following—

(1) A sinusoidal, time-varying flux, Φ , linking a conducting circuit produces a voltage, e , in the circuit proportional to $d\Phi/dt$ (i.e., Faraday's law of induction).

(2) The algebraic sum of the voltages around any closed path in a circuit is zero (i.e., Kirchhoff's voltage law).

(3) The voltage, v , in a circuit induced by a changing flux is always in the direction in which current would have to flow to oppose the changing flux (i.e., Lenz's law).

c. When the sinusoidal voltage, v , is impressed onto the primary electrical winding of N_1 turns, it is expected that a sinusoidal current, I , will begin to flow in the circuit, which in turn will produce a sinusoidally varying flux, Φ . For simplicity, it is assumed that all of the flux set up by the primary circuit lies within the transformer's iron core and it therefore links with all the turns of both windings. If the flux at any instant is represented by the equation:

$$\Phi = \Phi_m \sin 2\pi ft$$

where:

Φ_m = the maximum value of the flux
 f = the frequency
 t = time,




Figure 2-1 Simplified two-winding transformer

it follows from Faraday's law (i.e., $e = N d \Phi / dt$) that the instantaneous voltage e_1 induced in the primary winding is:

$$e_1 = 2\pi f N_1 \Phi_m \cos 2\pi f t$$

The polarity of e_1 will be according to Lenz's law, and hence will be in opposition to the impressed voltage, v (figure 2-1). The root mean square (rms) value of e_1 is

$$E_1 = (2\pi / \sqrt{2}) f N_1 \Phi_m = 4.44 f N_1 \Phi_m$$

d. Remembering Kirchhoff's voltage law, and assuming that the winding resistance is relatively small, E_1 must be approximately equal to V , where V represents the rms value of the applied voltage. One important result from this equation is that the value of the maximum flux, Φ_m , is determined by the applied voltage. In other words, for a given transformer, the maximum value of the flux is determined by the amplitude and frequency of the voltage applied to the primary winding. The same flux that caused E_1 in the primary winding will also induce a voltage across the terminals of the secondary winding. Thus, the only difference in the rms values of the two voltages will come from the difference in the number of turns. If the secondary winding has N_2 turns, the secondary voltage can be written as:

$$E_2 = 4.44 f N_2 \Phi_m$$

Dividing Equation 3 by Equation 4 gives the familiar relationship:

$$E_1/E_2 = N_1/N_2$$

e. Consider next when the transformer is loaded with a resistor R_{load} by closing the switch in the sec-

ondary circuit. If the core flux is in the direction indicated (with the flux increasing), then by Lenz's law, the polarity of E_2 will be such that current I_2 will flow in the secondary winding in attempt to decrease the core flux. The amount of secondary current that will flow will depend on the value of R_{load} (that is, $I_2 = E_2/R_{load}$), and the power delivered to the load will equal $E_2 I_2$. It is important to understand the mechanism by which the power is transferred from the primary circuit to the load. Consider a situation when current is suddenly allowed to flow in the secondary winding by closing the switch. As mentioned previously, the action of this current will be to decrease the core flux. Decreasing the core flux would lower the value of E_1 , which would be in violation of Kirchhoff's voltage law (KVL). Since KVL must be satisfied, more current must flow in the primary winding. The steady-state result is that the primary current will increase to the value sufficient to neutralize the demagnetizing action of the secondary current. It is important to realize that the resultant flux in the core remains the same regardless of the loading on the transformer. If the level of core flux were to vary with load, then E_1 and E_2 would also vary, which is contrary to what is observed in practice.

f. An iron core is used in transformers because it provides a good path for magnetic flux and directs the flux so it predominantly links all of the turns in each winding. However, the core has its limitations and can carry only so much flux before it becomes saturated. Core saturation occurs when all of the magnetic domains of the iron align, resulting in a condition in which no further increase in flux density over that of air can be obtained. Consider the magnetizing curve in figure 2-2, showing flux versus magnetizing current, where the magnetizing current i_m is the steady-state component of current




Figure 2-2. Magnetization curve for the transformer's iron core

required to establish the resultant flux level in the iron core for the transformer. It is typical for a transformer, or any other magnetic circuit, to be designed for operation close to the "knee" of this curve (i.e., Φ_{\max}) to use as much of the iron core as possible. Beyond Φ_{\max} , the iron saturates and it becomes extremely difficult to further increase the flux level. The curve implies that forcing the iron core into saturation can result in a significant increase in the value of the magnetizing current, and hence, can cause the windings to become overloaded and the transformer to overheat.

g. This study is concerned primarily with equipment sensitive to 50 Hz and voltage levels since the equipment will be used overseas where voltage frequencies and levels typically are different from those in the United States. This equipment could be listed by item, but a more useful format results when it is divided into classes and subclasses of equipment from which manufacturers for specific pieces of equipment can be easily selected. Following this format, listed below are the broad classes of equipment sensitive to 50 Hz and building voltage levels. Each section contains specific classes and subclasses of equipment. Additionally, each section describes why the equipment is sensitive to voltage frequency and or level. Equipment that does not readily fit into any other category is listed in paragraph 2-8.

2-2. Heating, ventilation, and air-conditioning (HVAC).

HVAC equipment includes boilers, furnaces, water chillers, humidifiers, fans, compressors, evaporators, and related equipment. Certain issues must be considered when using HVAC equipment in 50 Hz and alternate voltage environments, including the motor speed and step-down transformers for power supplies.

a. The objective of an HVAC system is to provide the necessary heating and cooling to a building according to the design specifications. Typically, alternating current (AC) motors are used in HVAC systems to drive fans, pumps, and compressors. When 60 Hz motor is run off a 50 Hz supply, the shaft speed of the motor is reduced by 5/6 since the motor speed is directly related to the frequency of the applied voltage. This speed will affect all direct-drive applications. For example, a pump that is directly coupled to the motor shaft will transfer less fluid over time if the shaft speed is reduced. Consequently, direct-drive HVAC applications must be derated to account for the reduced motor speed. However, for driven equipment that is tied to the motor through adjustable pulleys, the speed of the driven device can be increased to the necessary level.

b. Regardless of how the driven equipment is coupled to the motor, the 60 Hz motor must still operate within

its rating in the 50 Hz environment. For the motor to deliver the same mechanical power at a lower speed, it must deliver more torque since output power equals torque times the shaft speed. If the motor delivers more torque, more current will flow in the motor and an overloaded condition may result. Hence, a 60 Hz motor may have to be derated to handle the extra current flow.

c. Another concern with operating a 60 Hz motor with a 50 Hz voltage source is with saturating the iron core of the motor. Like the transformer, the maximum value of flux in the core depends directly on the amplitude of the applied voltage and inversely on the frequency. Assuming that the same voltage level is applied to the 60 Hz motor in the 50 Hz environment, the reduction in frequency to 50 Hz would require an increase in core flux of 20 percent (that is, 6/5 of its 60 Hz level). If the iron core of the motor is unable to provide the extra flux, the core will saturate, and a significant increase in the stator currents can result, causing the motor to overheat.

d. Step-down transformers typically are needed to transform local voltage levels to the levels the equipment is designed for. In most cases, the equipment contains some sort of step-down transformer that typically has to be changed to convert the higher input voltage to the same output voltage. In cases where no step-down transformer is in the equipment, one must be added to avoid burning out components by subjecting them to a higher supply voltage. Determining the need for a step-down transformer and adding it to the equipment is easily accomplished, and is discussed further in chapter 3. Equipment that cannot be purchased with the precise specifications needed must be purchased in U.S. specifications and then derated as described in chapter 3.

2-3. Electrical distribution and protection.

Electrical distribution equipment includes transformers, panelboards and switchboards, generators, transfer switches, capacitors, and related equipment. Electrical protection devices include fuses, circuit breakers, relays, reclosers, and contactors. The devices have different sensitivities to supply voltage and frequency, and are discussed below.

a. *Electrical distribution.* As mentioned earlier, transformers are sensitive to the frequency and amplitude of the supply voltage. Using a 60 Hz transformer in a 50 Hz electrical environment can cause the core of the transformer to saturate, overheating the transformer. Other than the potential problem with saturation, the transformer should be fully capable of supplying the nameplate rated load. Most transformers are available in 50 Hz or 50/60 Hz configurations, so saturation should not be a problem.

(1) Panelboards, switchboards, and load centers are generally not sensitive to supply frequency, except when protective devices such as circuit breakers are included in them. These items can be acquired readily in a wide variety of voltage ratings; therefore, supply voltage does not pose a problem.

(2) General output voltage can be increased or decreased by using an appropriate transformer. However, since generators are typically used to supply backup power when the utility power source fails, and or are used in addition to the utility power source, it is necessary for the generator to provide a 50 Hz voltage source to match the utility supply. Therefore the user must purchase a generator configured for 50 Hz operation.

(3) Automatic source transfer switches are sensitive to supply voltage frequency and amplitude because they are electronically controlled and have power supplies that expect to operate on 60 Hz and rated voltage. Once again, supply voltage level is not a problem since transformers are available to adapt voltage levels. Supply frequency, however, may be a problem depending on the type of power supply the electronics use.

(4) Related equipment includes meter centers, and sockets or receptacles. Meter centers are sensitive to voltage level and frequency. Consequently, using a 60 Hz meter center in a 50 Hz environment may result in inaccurate readings. However, meters are readily available in a variety of voltage levels and 50 Hz configurations.

(5) Sockets or receptacles are needed when foreign consumer products are to be used with the power system. Receptacles are configured for different voltage levels, and these configurations vary in different countries. It is important that the standard receptacle style for a given voltage be used to avoid confusing the user and creating a potential safety hazard.

(6) Capacitors are used in an electrical distribution system to adjust the power factor or phase angle between the voltage and current waveforms. It is desirable to have a phase angle close to zero, or a power factor close to one so that most of the power transferred to the load is real power. Real power is the only part of the total kilovolt-amperes transferred that can do work. The balance is called reactive power and cannot do any useful work. The operation of a capacitor depends on the supply frequency, since a capacitor's impedance, X_C , is related to the capacitance and frequency of the current passing through it by the equation $X_C = 1/(j2\pi fC)$, where C is the capacitance in farads and j equals the square root of -1.

b. Electrical protection. Electrical protection devices vary in their sensitivity to supply frequency. All protection devices are available in a wide range of voltage ratings so the level of the supply voltage is not a concern. The main concern with protection devices is the change in response time from 60 Hz to 50 Hz. These devices are coordinated to protect the distribution system from faults (shorts or spikes) but are connected so they do not trip when anticipated voltage spikes (that is, motor starting) occur. The power system design engineer must be sure to use the proper trip curves for the environment when coordinating protective devices. Trip curves for 50 Hz are readily available from vendors contacted in this study. The only device designed differently for 50 Hz and 60 Hz is the circuit breaker.

2-4. Medium voltage distribution equipment: 50 Hz → 60Hz.

In this section medium voltage transformers, switchgear and associated auxiliary devices will be examined with respect to frequency and voltage changes.

a. Medium voltage distribution transformers. Distribution transformers are key components in any electric power distribution system. It is important that they are properly matched to their environment. Issues related to operating a 60 Hz transformer from a 50 Hz power source were discussed earlier in this manual. The emphasis here will be on discussing issues concerning operating 50 Hz transformers in a 60 Hz environment.

(1) An important parameter to consider when operating a transformer, or other iron core-based devices, is the ratio of amplitude to frequency of the applied voltage. The ratio obtained using the nameplate rated voltage and frequency should be compared with the ratio available at the proposed site. If the ratio is less than or equal to that obtained using the nameplate quantities, magnetic saturation will not be a problem at the new site. Any time the ratio is higher than nameplate, the manufacturer should be contacted to ensure that the transformer has enough reserve available to accommodate the increase in operating magnetic flux density.

(2) For example, consider a transformer that is brought over from Germany where it was used on a 10 kV, 50 Hz distribution system. It was determined that the electrical insulation system of the transformer was rated for 15 kV. It is desired to use the transformer on a 13.8 kV, 60 Hz system. Considering the magnetic circuit, the volts-per-hertz ratio of the 50 Hz transformer is 200 (i.e., 10 kV/50 Hz). On the new supply the ration would be increased to 230 (that is, 13.8 kV/60 Hz), requiring a higher magnetic flux density in the iron core. This increase could potentially saturate the iron core and overheat the transformer. Alternatively, this

transformer could be used on a 7.2 kV/60 Hz system (120 volts-per-hertz ratio), where saturation would not be a problem.

(3) A few words should be mentioned concerning iron core loss in transformers. The two primary components of core loss are eddy-current loss and hysteresis loss. Eddy-current loss is the term used to describe the power loss associated with circulating currents that are found to exist in closed paths within the body of a iron material and cause undesirable heat production. Hysteresis loss represents the power loss associated with aligning and realigning the magnetic domains of iron in accordance with the changing magnetic flux. Both components are dependent on the frequency, as shown in the following equations:

$$P_{\text{eddy-current}} = K_e f^2 B_m^2 \tau^2 v$$

$$P_{\text{hysteresis}} = K_h f B_m^2 v$$

where,

- K = constant value dependent upon material
- f = frequency of variation of flux
- B = maximum flux density
- v = total volume of the material
- τ = lamination thickness.

(4) It should be noted that, even though frequency increases when using 50 Hz transformers on a 60 Hz-based system, the voltage-to-frequency ratio will typically be lower, and hence, the maximum flux densities B will be lower. The result is that core-losses will generally not increase as a result of the higher frequency used.

(5) Other key parameters are voltage and current. To maintain insulation system integrity, rated voltage and/or current for the transformer should not be exceeded. A transformer can be operated on lower than rated voltage; however, its current rating must not be violated. Also, the secondary voltage must be matched to the proper voltage levels.

(6) In addition to having an iron core, windings, and insulation system, distribution transformers may include tap changers and auxiliary devices. Auxiliary devices might include fans, current transformers, pressure relief devices, and lighting arresters. Once again, attention should be focused on devices that use a magnetic field for transferring or converting energy, such as instrument transformers and small motor drives. Even if the voltage-to-frequency ratio is found to be lower, manufacturers should be contacted to make sure that all linear and rotating drive mechanisms will develop adequate force and torque to function properly.

b. Medium voltage switchgear. Switchgear is a general term covering switching and interrupting devices alone, or their combination with other associated control, metering, protective, and regulating equipment. Common switchgear components include the power bus, power circuit breaker, instrument transformers, control power transformer, meters, control switches, protective relays and ventilation equipment. The ratings of switchgear assemblies are designations of the operational limits under specific conditions of ambient temperature, altitude, frequency, duty cycle, etc. For example, the performance of some 50 Hz magnetic type circuit breakers may be altered slightly when operated on a 60 Hz power system. Switchgear manufacturers should always be consulted to identify the frequency response of circuit breakers and all auxiliary devices.

2-5. Safety and security equipment.

Safety and security equipment includes fire detection systems, burglar alarm systems, doorbells, and surveillance systems. This equipment typically operates on low voltage, either alternating current (AC) or direct current (DC), generated initially by a power supply. Acquiring the proper power supply to convert from the supply voltage to the low voltage that these systems expect (typically 6 to 12 VAC or VDC) is the key to proper operation of these systems in foreign environments. Power supplies of 50 Hz/120 VAC usually are available from vendors of these systems, and a transformer can be used to step a 240 VAC supply down to a 120 VAC foreign environment. Therefore, derating is not necessary for these items, although a transformer may be needed to step high voltage supply levels down to 120 VAC for the power supplied to these systems. Most vendors of safety and security equipment can configure their equipment to 50 Hz and a variety of voltage levels.

2-6. Communication equipment.

Communication equipment encompasses public address systems and sound systems, both of which operate on a low-voltage DC supply generated by a power supply. Power supplies are available to operate on 50 Hz and 240 V supply voltages. In cases where only 120/50 Hz supplies are available, a step-down transformer can be used to step a 240 V supply down to 120 V. The vendors contacted in this study have stated that they provide 50 Hz power supplies.

2-7. Lighting.

Lighting can be divided into incandescent, fluorescent, and high intensity discharge (HID) categories. Incandescent lighting is not frequency-sensitive, whereas fluorescent and HID lights are started by a ballast that is sensitive to voltage level and frequency.

All types of lighting are sensitive to the supply voltage level and cannot be derated for voltage. For example, subjecting a 120 V incandescent lamp to a 240 V source will result in the lamp burning twice as hot, causing rapid lamp failure. Subjecting the iron core ballast use in many HID and fluorescent fixtures to twice its rated voltage will saturate the ballast and will subject the fixture to much more than its rated current. As with transformers and motors, 60 Hz iron-core ballasts can also be saturated when operated at 50 Hz. At first thought, frequency dependence may not be as much of a problem with electronic ballasts since, in most cases, the AC voltage source is first converted back to a high frequency AC source, and therefore, the voltage source that is actually impressed across the lamp is decoupled from the 60 Hz AC source. However, the power supply used to power the electronics in these ballasts must be capable of 50 Hz operation.

2-8. Other electrical equipment.

Other electrical equipment includes motors, motor starters, computer power supplies, and clocks.

a. Typically, motor starters are sensitive to both supply voltage level and frequency. The most commonly used

motor starters consists of a coil, thermal overloads, and a set of contactors (contacts). The thermal overloads, which are essentially circuit breakers, and the contactors are rated to handle a certain amount of current. Since at 50 Hz, a motor of a given horsepower rating will draw more current than an identically-rated motor would draw at 60 Hz, the thermal overloads and the contactors must be sized accordingly.

b. Computer power supplies include voltage regulators, isolation transformers, transient voltage suppressor transformers, computer regulator transformers, and power conditioning transformers. Computer power supplies are sensitive to both frequency and voltage level.

c. Clocks are sensitive to supply frequency and voltage. Clocks rely on the frequency of the supply voltage to keep correct time, so a clock designed for 60 Hz will not keep correct time at 50 Hz. The motor that runs the clock is also sensitive to supply voltage level. Therefore, a clock must either be purchased configured for the supply voltage level, or a transformer must be used to convert the supply voltage level to the clock's rated voltage level. Clocks cannot be derated for frequency, and therefore clocks designed for 50 Hz must be purchased.

CHAPTER 3

EQUIPMENT DERATING

3-1. Derating under 50 Hz conditions.

Derating factors for 50 Hz operation are developed differently for different types of equipment. Derating factors for HVAC, electrical distribution and protection, safety and security equipment, communication equipment, lighting, and other electrical equipment are discussed below.

3-2. Heating, ventilating, and air conditioning (HVAC) for derating.

The frequency of the supply voltage affects two types of components in HVAC systems: motors and controls. From the discussion in paragraph 2-2, for the same mechanical load and voltage level, a 60 Hz motor will draw 20 percent more current when supplied from a 50 Hz voltage source. This assumes the iron core of the motor does not saturate. Therefore, a 60 Hz motor would have to be capable of handling the increase in current level. However, as was also mentioned in the previous chapter, saturation can be a serious problem when running a 60 Hz motor off a supply frequency of 50 Hz. Developing a derating factor to account for saturation is not possible, since the motor designs vary from vendor to vendor, and hence, the degree of saturation that would occur, if any, would be impossible to predict. Consequently, it is recommended that no horsepower derating be performed, and a 50 Hz motor be purchased.

a. However, if the vendor can guarantee the user that a given 60 Hz motor would not saturate at 50 Hz, then the motor would need only to be derated to handle the 20 percent increase in current level. The amount of horsepower derating required would depend on the motor's mechanical load, service factor, and thermal limit. The service factor is a measure of how much the motor can be overloaded continuously without exceeding safe temperature limits. The thermal limit is the minimum speed at which an AC motor can be operated with rated amperes, without exceeding safe temperature rise. The thermal limit is important because the motor's ability to cool itself will be reduced at lower speeds unless, of course, some sort of auxiliary cooling is used. In most cases, however, the minimum shaft speed necessary to exceed the thermal limit is much lower than 1500 revolutions per minute (RPM, for example, for a 4-pole motor), so 50 Hz operation should not be a problem, although the vendor should be contacted for verification. A 60 Hz motor with a 1.20 service factor can be

operated safely while overloaded continuously by 20 percent. The same motor can be operated safely with a rated mechanical load and a 50 Hz power supply with no horsepower derating, assuming saturation is not an issue, the thermal limit of the motor is not exceeded, and the same voltage amplitude is applied. However, a 60 Hz motor, with a 1.0 service factor, driving a rated mechanical load would have to be derated for horsepower by 20 percent, since it is not capable of handling greater than the rated current. In summary, the user should find out the service factor and thermal limit of the motor to determine the amount of horsepower derating required, and to ensure that the 20 percent increase in current level in the motor does not exceed the motor's rating (again, assuming saturation is not a concern).

b. Another issue to be considered when purchasing HVAC equipment for a 50 Hz environment is that the motor's shaft will spin 5/6 as fast as it would with a 60 Hz supply. For a 4-pole motor, the shaft will rotate at roughly 1500 RPM when run off a 50 Hz supply, where as with a 60 Hz voltage source it will rotate at about 1800 RPM. Consequently, equipment that is directly coupled to the shaft of the motor will rotate at 5/6 the speed it would in a 60 Hz environment. Hence, direct-drive equipment must be derated to account for the change in speed. In cases where the equipment is indirectly coupled to the motor shaft, through the use of adjustable pulleys for example, the reduction in shaft speed is not as much of a problem since the required speed of rotation can be obtained through the proper adjustment or selection of the pulleys.

c. Additionally, electronic HVAC controls that contain their own power supply may be 50 Hz sensitive. Most of the vendors contacted stated that this typically is not a problem because most controls are frequency-sensitive. If the control are 50 Hz sensitive, they must be purchased in a 50 Hz configuration. The HVAC vendor must be consulted on a case-by-case basis to determine if the controls can be used in 50 Hz environments.

3-3. Electrical distribution and protection.

In general, a 60 Hz transformer should not be used with a 50 Hz voltage source because of the potential saturation problem. As with motors, a derating factor cannot be developed to account for saturation because of the many different transformer designs on the market. It is recommended that a 50 Hz transformer be pur-

chased for use with a 50 Hz voltage source. However, if a 60 Hz transformer vendor can ensure that a transformer will not saturate when operated at 50 Hz, the transformer should be fully capable of safely supplying its nameplate rated load (that is, no horsepower derating is required). In terms of the transformer's equivalent impedance, sometimes used for power system studies (for example, short-circuit and load-flow analysis), the 60 Hz value should be derated by 5/6 to account for the reduction in system frequency.

a. Power factor capacitors rated at 60 Hz must also be derated to 50 Hz. Capacitors do not consume any real power, but they do consume reactive power. The rating given to power factor capacitors is given in units of kilovolt-amperes reactive (KVAR), which indicates the amount of reactive power the capacitor will consume at the rated frequency. As mentioned in chapter 2, the capacitor's impedance, X_c , is inversely related to frequency. If the frequency drops from 60 to 50 Hz, the impedance will increase to 6/5 of its 50 Hz value. Since the KVAR rating equals V^2/X_c , if X_c at 50 Hz increases to 6/5 of its 60 Hz rating, the KVAR rating will decrease to 5/6 of its 60 Hz rating when the capacitor is used in a 50 Hz environment. Therefore, a 60 Hz-rated capacitor must have the KVAR rating multiplied by 5/6 to yield its 50 Hz KVAR rating.

b. Other electrical protection and distribution equipment either cannot or should not be derated. Electrical protection devices are generally able to be used at either 50 Hz or 60 Hz, but a different trip curve needs to be used by the power system designer for 50 Hz. These 50 Hz trip curves are readily available from vendors of this equipment, so no derating is necessary. The only exception is that some circuit breakers are designed differently at 50 Hz and 60 Hz.

c. Voltage, current, and power meters can be derated, but this practice is not recommended. A meter should display the true value it is supposed to measure to ensure that the readings are interpreted correctly and that no dangerous situations result. Meters, therefore, should not be derated. Automatic transfer switches use power supplies that may or may not be frequency-sensitive. Vendors must be contacted regarding 50 Hz configuration of these devices. Electrical generators must be purchased already configured to provide a 50 Hz voltage source.

3-4. Safety and security equipment for derating.

Safety and security equipment operate on a low-voltage AC or DC source that is generated by a power supply. Some power supplies are sensitive to frequency; others are not. In either case, derating is not necessary since power supplies sensitive to frequency can-

not be derated, and power supplies insensitive to frequency do not need to be derated. In cases where the power supplies are sensitive to 50 Hz, vendors are able to ship the equipment with a 50 Hz-compatible power supply.

3-5. Communication equipment for derating.

Communication equipment operates on a low-voltage DC supply and does not need to be derated for frequency. Vendors will either ship the units with frequency-insensitive power supplies, or they will configure the units for 50 Hz operation before shipping.

3-6. Lighting for derating.

Incandescent lighting is not frequency-sensitive since this type of lighting consists of a resistive element (the filament), which is not frequency-sensitive. Fluorescent and high intensity discharge (HID) lighting, on the other hand, use a ballast to generate the proper lamp voltage and to limit the current flowing through the lamp. These ballasts are sensitive to frequency. Because of the numerous ballast designs and styles on the market, and the potential saturation problem, a simple derating factor cannot be developed and it is recommended that a vendor supplying 50 Hz-rated ballasts be located.

3-7. Other electrical equipment for derating.

Other electrical equipment consists of motors, motor starters, computer power supplies, and clocks. Motor derating was mentioned earlier in the HVAC section of this chapter. Motor starters are sensitive to frequency as well, but indirectly so. Since a 60 Hz motor will draw 20 percent more current when operated off a 50 Hz voltage source, assuming the same voltage amplitude is applied and there is no saturation problem, the motor starter current rating must be derated by 20 percent to account for the increase in current. Clocks and computer supply equipment are sensitive to frequency and cannot be derated. Clocks rely on the frequency of the supply to keep correct time, so a 60 Hz clock will not keep correct time at 50 Hz. Although derating factors could be developed for clocks, they would be meaningless. Computer power supply equipment cannot be derated due to the way the equipment is constructed.

3-8. Derating under alternate voltage conditions.

As appendix B shows, standard one-phase voltages around the world are either in the range of 100-127 VAC or 220-240 VAC. Voltage variations within about 10 percent of an equipment's rated voltage are acceptable, so derating for voltage will only be necessary when a piece of equipment rated for U.S. voltage (approximately 120 VAC) needs to be operated in an environment using 220-240 VAC. This would be a doubling of rated voltage. None of the equipment sensitive to voltage level is capable of surviving this increase

without rapid failure. Thus, no derating factors for voltage level are offered. Instead, it is recommended that transformers be used to step the higher voltage level down to a voltage level in the range of 100-127 VAC, which U.S. equipment can tolerate. It has been found, however, that most vendors of voltage-sensitive equipment are able to configure the equipment for 220-240 VAC and corresponding three-phase voltage levels.

3-9. Recommendations.

Derating factors were discussed and developed for the six generic types of equipment. Appendix C, which summarizes the discussion of derating factors presented in this chapter, is useful in identifying derating factors quickly and easily. Although this chapter presents derating factors for equipment, it is recommended that, whenever a piece of equipment is to be derated, the

vendor be contacted to discuss the derating. It is always preferable to locate a vendor that will supply the equipment with the desired ratings before derating is attempted. The majority of vendors contacted are able to supply equipment rated at 50 Hz and a variety of voltage levels, so derating should be necessary in only a few cases.

3-10. Summary.

Appendix B can be used to rapidly identify the standard frequency and voltage levels in other countries. In cases where cities within a country differ in their electrical standards, the cities are listed separately. For countries in which all cities have the same electrical standards, typically only the capital city is listed. In these cases, assume that all cities in the country have the same electrical standards.

APPENDIX A

References

Electrical Current Abroad-1998 Edition (U.S. Department of Commerce, Bureau of Industrial Economics, Superintendent of Documents, PO. Box 371954, Pittsburgh, PA 15250-7954, Stock Number 003-009-00673-2).

International Directory of Electric Utilities, 9th ed. (Utility Data Institute [Division of McGraw-Hill], 1200 G St., NW, Suite 250, Washington, DC 20005, January 1996).

World Electricity Supplies (British Standards Institution, 389 Chiswick High Rd., London W4 4AL, England, 1975).

DellToro, Vincent, *Basic Electric Machines* (Prentice Hall, One Lake St., Upper Saddle River, NJ 07458, 1990)

Elgerd, Olle I., *Electrical Energy Systems Theory: An Introduction* (McGraw-Hill Companies, Two Penn Plaza, 9th Floor, New York, NY 10121-2298, 1971)

Fitzgerald, A. E., Charles Kingsley, and Stephen Umans, *Electric Machinery-Fifth Edition* (McGraw-Hill Companies, Two Penn Plaza, 9th Floor, New York, NY 10121-2298, 1990)

Information Handling Services (IHS Engineering Products, 15 Inverness Way East, Englewood, CO 80112)

Lawrence, Ralph, and Henry Richards, *Principles of Alternating Current Machinery-Fourth Edition* (McGraw-Hill Companies, Two Penn Plaza, 9th Floor, New York, NY 10121-2298, 1953)

Means Electrical Cost Data-14th Annual Edition (R. S. Means Company, Inc., Construction Plaza, 63 Smiths Lane, Kingston, MA 02364-0800, 1990)

Means Mechanical Cost Data-9th Annual Edition (R. S. Means Company, Inc., Construction Plaza, 63 Smiths Lane, Kingston, MA 02364-0800, 1990)

APPENDIX B

Frequency and Single- and Three-Phase Voltage Levels by Country

This appendix covers identification of various low and medium voltage levels, along with the system frequencies, used by countries around the world.

Table B-1. Frequency and Single and Three-Phase Voltage Levels by Country

| Country/City | Frequency (Hz) | Number of Phases | Low Voltage (V) | Medium Voltage (kV) |
|----------------|----------------|------------------|--------------------|-------------------------------------|
| Afghanistan | 50 | 1,3 | 220/380 | 3.2, 6, 10, 15, 20 |
| Algeria | 50 | 1,3 | 127/220 220/380 | 5.5, 6.6, 10, 30 |
| American Samoa | 60 | 1,3 | 120/240 240/480 | NA |
| Angola | 50 | 1,3 | 220/380 | NA |
| Antigua | 60 | 1,3 | 230/400 | NA |
| Argentina | 50 | 1,3 | 220/380 | 6.6, 13.2, 33 |
| Australia | 50 | 1,3 | 240/415 | 6.6, 7.6, 11, 12.7, 19, 22, 33, 66 |
| Austria | 50 | 1,3 | 220/380 | 3, 5, 6, 10, 20, 25, 28, 30 |
| Azores | | | | NA |
| Ponta Delgada | 50 | 1,3 | 110/190 220/380 | |
| All Others | 50 | 1,3 | 220/380 | |
| Bahamas | 60 | 1,3 | 120/240 120/208 | 7.2, 11 |
| Bahrain | | | | 11 |
| Awali | 60 | 1,3 | 230/400 | |
| All Others | 50 | 1,3 | 230/400 | |
| Bangladesh | 50 | 1,3 | 220/380 | 11, 33 (various seasonally) |
| Barbados | 50 | 1,3 | 115/230 115/200 | 11,24 |
| Belgium | | | | 6.6, 10, 15, 36, 70* |
| Anderlecht | 50 | 1,3 | 220 | |
| Antwerpen | 50 | 1,3 | 127/220 220/380 | |
| Brugge | 50 | 1,3 | 220/380 | |
| Brussels | 50 | 1,3 | 127/220 220/380 | |
| Charlerio | 50 | 1,3 | 230/400 | |
| Gentbrugge | 50 | 1,3 | 220/380 | |
| Hasselt | 50 | 1,3 | 130/220 220/380 | |
| Hoboken | 50 | 1,3 | 127/220 220/380 | |
| Huy | 50 | 1,3 | 220 | |

*Voltages listed are country-inclusive, all voltages listed for the country may not be found in individual cities listed.

Table B-1. Frequency and Single and Three-Phase Voltage Levels by Country—Continued

| Country/City | Frequency (Hz) | Number of Phases | Low Voltage (V) | Medium Voltage (kV) |
|------------------------------|----------------|------------------|--------------------|------------------------------|
| Belgium (continued) | | | | |
| Jette | 50 | 1,3 | 127/220 | |
| Leige | 50 | 1,3 | 220/380 | |
| Liege-Monsinport | 50 | 1,3 | 110/220 220/380 | |
| Lokeren | 50 | 1,3 | 220/380 | |
| Leuven | 50 | 1,3 | 220/380 | |
| Mechelen | 50 | 1,3 | 220/380 | |
| Mons | 50 | 1,3 | 220/380 | |
| Namur | 50 | 1,3 | 220/380 | |
| Oostende | 50 | 1,3 | 127/220 220/380 | |
| Ronse | 50 | 1,3 | 220/380 | |
| Seraing | 50 | 1,3 | 220/280 | |
| Turnhout | 50 | 1,3 | 220 | |
| Uccle | 50 | 1,3 | 220/380 | |
| Vilvoorde | 50 | 1,3 | 120/220 220/380 | |
| Belize | | | | 6.6, 22* |
| Belize City | 60 | 1,3 | 110/220 220/440 | |
| Balmopan | 60 | 1,3 | 110/220 220/240 | |
| Corozal Town | 60 | 1,3 | 110/220 220/440 | |
| Orange Walk | 60 | 1 | 110/220 | |
| San Ignacio | 60 | 1 | 110/220 | |
| Stann Creek | 60 | 1 | 110/220 | |
| Punta Gorda | 60 | 1,3 | 110/220 220/440 | |
| San Pedro | 60 | 1 | 110/220 | |
| Benin | 50 | 1,3 | 220/380 | 15, 20 |
| Bermuda (Island-wide) | 60 | 1,3 | 120/240 120/208 | NA |
| Bolivia | | | | 6.6, 24.9* |
| Calamarca | 50 | 1,3 | 230/400 | |
| Challapata | 50 | 1,3 | 220/380 | |
| Cobija | 50 | 1,3 | 230/400 | |
| Cochabamba | 50 | 1,3 | 220/380 | |
| Guayaramerin | 50 | 1,3 | 230/400 | |
| La Paz | 50 | 1,3 | ??/230 | |
| Potosi | 50 | 1,3 | 220/380 | |
| Oruro | 50 | 1,3 | 110/220 | |
| Riberalta | 50 | 1,3 | 230/400 | |
| Santa Cruz | 50 | 1,3 | 220/380 | |
| Sucre | 50 | 1,3 | 220/380 | |
| Trinidad | 50 | 1,3 | 230/400 | |
| Tupiza | 50 | 1,3 | 220/380 | |
| Viacha | 50 | 1,3 | 110/220 | |
| Villazon | 50 | 1,3 | 220/380 | |
| Bosnia/Herzegovina | NA | NA | NA | 6.6, 10 |
| Botswana | 50 | 1,3 | 220/380 | 11, 33, 66 |
| Brazil | | | | 6, 11.4, 13.8, 22, 25, 34.5* |
| Barbacena | 60 | 1,3 | 110/220 | |
| Blumenau | 60 | 1,3 | 220 | |
| Braganca | 60 | 1,3 | 110/220 | |

Foreign Voltages and Frequency - E04-029

| Country/City | Frequency (Hz) | Number of Phases | Low Voltage (V) | Medium Voltage (kV) |
|---------------------------|----------------|------------------|-----------------|---------------------|
| <i>Brazil (continued)</i> | | | | |
| Brasilia | 60 | 1,3 | 220/380 | |
| Caxias do Sul | 60 | 1,3 | 220/380 | |
| Cel Fabriciano | 60 | 1,3 | 110/220 | |
| Corumba | 60 | 1,3 | 110/220 | |
| Florianopolis | 60 | 1,3 | 220/380 | |
| Fortaleza | 60 | 1,3 | 230/400 | |
| Goiania | 60 | 1,3 | 220/380 | |
| Goiias | 60 | 1,3 | 220/380 | |
| Itajai | 60 | 1,3 | 220 | |
| Joao Pessoa | 60 | 1,3 | 220 | |
| Joinville | 60 | 1,3 | 220/380 | |
| Jundiai | 60 | 1,3 | 110 | |
| Livramento | 60 | 1,3 | 220/380 | |
| Londrina | 60 | 1,3 | 127/220 | |
| | | | 110/220 | |
| Macapa | 60 | 1,3 | 110/220 | |
| Maceio | 60 | 1,3 | 220/380 | |
| Manaus | 60 | 1,3 | 120/240 | |
| Mossoro | 60 | 1,3 | 220/380 | |
| Natal | 60 | 1,3 | 220/380 | |
| Nava Friburgo | 60 | 1,3 | 220 | |
| Olinda | 60 | 1,3 | 127/220 | |
| | | | 220/380 | |
| Paranagua | 60 | 1,3 | 110/220 | |
| Parnaiba | 60 | 1,3 | 110/220 | |
| Pelotas | 60 | 1,3 | 220/380 | |
| Petropolis | 60 | 1,3 | 127/220 | |
| | | | 115/220 | |
| Ponto Grossa | 60 | 1,3 | 220 | |
| Porto Velho | 60 | 1,3 | 110/220 | |
| Santo Andre | 60 | 1,3 | 115/230 | |
| Sao Bernaroo do Campo | 60 | 1,3 | 115/230 | |
| Sao Caetano do | 60 | 1,3 | 110/220 | |
| Sul | 60 | 1,3 | 110/220 | |
| Sao Luis | 60 | 1,3 | 115/230 | |
| Sao Paulo | 60 | 1,3 | 110/220 | |
| Teresina | 60 | 1,3 | 125/216 | |
| Volta Rendonda | 60 | 1,3 | 127/220 | |
| All Others | | | | |
| Brunai | NA | NA | NA | 11, 68 |
| Bulgaria | 50 | 1,3 | 220/380 | NA |
| Burma/Myanmar | 50 | 1,3 | 230/400 | 3.3, 6.6, 11, 33 |
| Burundi | 50 | 1,3 | 220/380 | 6.6, 15 |
| Cambodia | | | | 4.4, 6.3, 15* |
| Phnom-Penh | 50 | 1,3 | 220/380 | |
| Sihanoukville | 50 | 1,3 | 220/380 | |
| All Others | 50 | 1,3 | 120/208 | |
| Cameroon | | | | 10, 15, 30, 33, 55* |
| Buea | 50 | 1,3 | 230/400 | |
| Eseka | 50 | 1,3 | 127/220 | |
| Maroua | 50 | 1,3 | 127/220 | |
| Mbalmayo | 50 | 1,3 | 127/220 | |
| | | | 220/380 | |
| Nkongsamba | 50 | 1,3 | 127/220 | |
| | | | 220/380 | |
| Sangmelima | 50 | 1,3 | 127/220 | |
| | | | 220/380 | |

Table B-1. Frequency and Single and Three-Phase Voltage Levels by Country—Continued

| Country/City | Frequency (Hz) | Number of Phases | Low Voltage (V) | Medium Voltage (kV) |
|--------------------------|----------------|------------------|--------------------|--|
| Cameroon (continued) | | | | |
| Victoria | 50 | 1,3 | 230/400 | |
| Yaounde | 50 | 1,3 | 127/220 220/380 | |
| All Others | 50 | 1,3 | 220/380 | |
| Canada | 60 | 1,3 | 120/240 | 2.4, 4.16, 7.2, 8, 12.47, 13.8, 14.4, 20, 25, 34.5, 44, 49 |
| Canary Islands | 50 | 1,3 | 127/220 220/380 | NA |
| Cape Verde (Praia) | 50 | 1,3 | 220/380 | 6, 6.3, 13, 15, 20 |
| Cayman Islands | 60 | 1,3 | 120/240 | NA |
| Central African Republic | 50 | 1,3 | 220/380 | NA |
| Chad | 50 | 1,3 | 220/380 | 15 |
| Channel Islands | | | | 11 |
| Alderney | 50 | 1,3 | 240/415 | |
| Guernsey | 50 | 1,3 | 230/400 | |
| Jersey | 50 | 1,3 | 240/415 | |
| Chile | 50 | 1,3 | 220/380 | 12, 13.2, 13.8, 15, 23 |
| China | 50 | 1,3 | 220/380 | 10, 20, 35 |
| Colombia | | | | 4.16, 7.6, 13.2, 13.8, 33, 34.5, 44* |
| Bogata | 60 | 1,3 | 150/240 | |
| Duitama | 60 | 1,3 | 120/208 | |
| Honda | 60 | 1,3 | 120/208 | |
| Sogomosa | 60 | 1,3 | 120/240 | |
| All Others | 60 | 1,3 | 110/220 | |
| Congo | 50 | 1,3 | 220/380 | 5.5, 6.6, 10, 20 |
| Costa Rica | 50 | 1,3 | 120/240 | 4.2, 13.2, 24.9, 34.5 |
| Croatia | 50 | 1,3 | 220/380 | 10,35 |
| Cyprus | 50 | 1,3 | 240/415 | 11 |
| Czech Republic | 50 | 1,3 | 220/380 | 6, 10 (urban) 22, 35 (rural) |
| Denmark | 50 | 1,3 | 220/380 | 6, 10, 20, 30 |
| Djibouti | 50 | 1,3 | 220/380 | NA |
| Dominican Republic | 60 | 1,3 | 110/220 | 2.5, 4.16, 12.5 |
| Ecuador | | | | 13.8, 34.5, 46, 69* |
| Cuenca | 60 | 1,3 | 120/208 | |
| Esmeraldas | 60 | 1,3 | 120/208 120/240 | |
| Guaranda | 60 | 1,3 | 120/208 120/240 | |
| Ibarra | 60 | 1,3 | 127/220 | |
| Latacunga | 60 | 1,3 | 120/208 | |
| Loja | 60 | 1,3 | 127/220 | |
| Machaia | 60 | 1,3 | 127/220 | |

Foreign Voltages and Frequency - E04-029

| Country/City | Frequency (Hz) | Number of Phases | Low Voltage (V) | Medium Voltage (kV) |
|------------------------------|----------------|------------------|-----------------|---------------------------|
| <i>Ecuador (continued)</i> | | | | |
| Morona | 60 | 1,3 | 120/208 | |
| Portoviejo | 60 | 1,3 | 127/220 | |
| Puyo | 60 | 1,3 | 127/220 | |
| Quito | 60 | 1,3 | 120/208 | |
| | | | 127/220 | |
| Riobamba | 60 | 1,3 | 110/220 | |
| Tulcan | 60 | 1,3 | 121/210 | |
| | | | 127/220 | |
| Zamora | 60 | 1,3 | 121/210 | |
| | | | 127/220 | |
| All Others | | | 120/208 | |
| | | | 127/220 | |
| Egypt | 50 | 1,3 | 220/380 | 3, 6.6, 11, 20, 33, 66 |
| El Salvador | 60 | 1,3 | 115/230 | 4.16, 4.4, 13.2, 23, 34.5 |
| England (see United Kingdom) | | | | |
| Equatorial Guinea | 50 | 1 | 220 | NA |
| Ethiopia | 50 | 1,3 | 220/380 | 15 |
| Faroe Islands | 50 | 1,3 | 220/380 | NA |
| Fiji | 50 | 1,3 | 240/415 | 11 |
| Finland | 50 | 1,3 | 220/380 | 10, 20, 30, 45 |
| France | | | | 3.3, 5.5, 10, 15, 20, 30* |
| l'Alpe d'Huez | 50 | 1,3 | 127/220 | |
| | | | 220/380 | |
| Alencon | 50 | 1,3 | 127/220 | |
| | | | 220/380 | |
| Amiens | 50 | 1,3 | 115/220 | |
| | | | 220/380 | |
| Angers | 50 | 1,3 | 127/220 | |
| | | | 220/380 | |
| Angouleme | 50 | 1,3 | 127/220 | |
| | | | 220/380 | |
| Annecy | 50 | 1,3 | 127/220 | |
| | | | 220/380 | |
| Arcachon | 50 | 1,3 | 127/220 | |
| | | | 220/380 | |
| Argenteuil | 50 | 1,3 | 127/220 | |
| | | | 220/380 | |
| Asnieres | 50 | 1,3 | 115/200 | |
| | | | 220/380 | |
| LaBaule | 50 | 1,3 | 127/220 | |
| | | | 220/380 | |
| Besancon | 50 | 1,3 | 127/220 | |
| | | | 220/380 | |
| Beziers | 50 | 1,3 | 127/220 | |
| | | | 220/380 | |
| Biarritz | 50 | 1,3 | 127/220 | |
| | | | 220/380 | |
| Boulogne-sur-Mer | 50 | 1,3 | 127/220 | |
| | | | 220/380 | |
| la Bourboule | 50 | 1,3 | 127/220 | |
| | | | 220/380 | |
| Bourges | 50 | 1,3 | 127/220 | |
| | | | 220/380 | |
| Bourg-En-Bresse | 50 | 1,3 | 127/220 | |
| | | | 220/380 | |

Table B-1. Frequency and Single and Three-Phase Voltage Levels by Country—Continued

| Country/City | Frequency (Hz) | Number of Phases | Low Voltage (V) | Medium Voltage (kV) |
|--------------------|----------------|------------------|-------------------------------|---------------------|
| France (continued) | | | | |
| Brest | 50 | 1,3 | 127/220 220/380 | |
| Briançon | 50 | 1,3 | 115/200 | |
| Cabourg | 50 | 1,3 | 127/220 220/380 | |
| Caen | 50 | 1,3 | 127/220 | |
| Calais | 50 | 1,3 | 115/220 220/380 | |
| Cauterets | 50 | 1,3 | 127/220 | |
| Chalons | 50 | 1,3 | 127/220 220/380 | |
| Chateauroux | 50 | 1,3 | 120/208 220/380 | |
| Chaumont | 50 | 1,3 | 120/208 220/380 | |
| Cherbourg | 50 | 1,3 | 127/220 220/308 | |
| Chinon | 50 | 1,3 | 127/220 220/308 | |
| Clermont-Ferrand | 50 | 1,3 | 127/220 220/308 | |
| Collioure | 50 | 1,3 | 127/220 220/380 | |
| Courbevoie | 50 | 1,3 | 115/230 | |
| Deauville | 50 | 1,3 | 127/220 220/380 | |
| Dieppe | 50 | 1,3 | 127/220 220/380 | |
| Dijon | 50 | 1,3 | 127/220 220/380 | |
| Dinan | 50 | 1,3 | 127/220 220/380 | |
| Douai | 50 | 1,3 | 127/220 220/380 | |
| Dreux | 50 | 1,3 | 127/220 220/380 | |
| Etain | 50 | 1,3 | 115/200 220/380 | |
| Evreux | 50 | 1,3 | 127/220 | |
| Fontainebleau | 50 | 1,3 | 127/220 220/380 | |
| Frejus | 50 | 1,3 | 127/220 220/380 | |
| Grenoble | 50 | 1,3 | 127/220 | |
| LeHavre | 50 | 1,3 | 110/190 127/220 220/380 | |
| Jouge | 50 | 1,3 | 127/220 220/380 | |
| Juan-les-Pins | 50 | 1,3 | 127/220 | |
| Lens | 50 | 1,3 | 127/220 220/380 | |
| Lille | 50 | 1,3 | 110/220 220/380 | |
| Luchon | 50 | 1,3 | 127/220 220/380 | |
| Luxeuil-Bains | 50 | 1,3 | 127/220 220/380 | |
| Lyon | 50 | 1,3 | 110/220 127/220 220/380 | |
| LeMans | 50 | 1,3 | 127/220 220/380 | |
| Marly-le-Roi | 50 | 1,3 | 127/220 220/380 | |

Foreign Voltages and Frequency - E04-029

| Country/City | Frequency (Hz) | Number of Phases | Low Voltage (V) | Medium Voltage (kV) |
|-------------------------|----------------|------------------|-------------------------------|---------------------|
| France (continued) | | | | |
| Marseille | 50 | 1,3 | 115/200 220/380 | |
| Megev | 50 | 1,3 | 127/220 | |
| Metz | 50 | 1,3 | 110/190 220/380 | |
| Lemont-Dore | 50 | 1,3 | 127/220 220/380 | |
| Motlucon | 50 | 1,3 | 127/220 220/380 | |
| Morzine | 50 | 1,3 | 127/220 220/380 | |
| Mulhouse | 50 | 1,3 | 230 220/380 | |
| Nancy | 50 | 1,3 | 127/220 220/380 | |
| Nantes | 50 | 1,3 | 110/190 | |
| Neuilly | 50 | 1,3 | 115/230 127/220 220/380 | |
| Nice | 50 | 1,3 | 127/220 | |
| Nimes | 50 | 1,3 | 220 220/380 | |
| Orleans | 50 | 1,3 | 127/220 | |
| Paris | 50 | 1,3 | 115/230 | |
| Perpignan | 50 | 1,3 | 127/220 220/380 | |
| Roanne | 50 | 1,3 | 127/220 220/380 | |
| LaRochelle | 50 | 1,3 | 115/200 127/220 220/380 | |
| Roubaix | 50 | 1,3 | 220/380 | |
| Royan | 50 | 1,3 | 127/220 220/380 | |
| Saint-Etienne | 50 | 1,3 | 115/230 127/220 220/380 | |
| Saint-Gervais-Les-Bains | 50 | 1,3 | 127/220 220/380 | |
| Saint-Jean-de-Lux | 50 | 1,3 | 380 | |
| Saint Lo | 50 | 1,3 | 127/220 220/380 | |
| Saint Quentin | 50 | 1,3 | 127/220 220/380 | |
| Sallanches | 50 | 1,3 | 127/220 | |
| Strasbourg | 50 | 1,3 | 125/220 220/380 | |
| Tabes | 50 | 1,3 | 115/200 220/380 | |
| Toulon | 50 | 1,3 | 127/220 220/380 | |
| Tourcoing | 50 | 1,3 | 110/220 220/380 | |
| Tours | 50 | 1,3 | 127/220 | |
| Val d' Iserre | 50 | 1,3 | 127/220 220/380 | |
| Valenciennes | 50 | 1,3 | 127/220 220/380 | |
| Valloire | 50 | 1,3 | 127/220 | |
| Verdun | 50 | 1,3 | 127/220 220/380 | |
| Versailles | 50 | 1,3 | 127/220 220/380 | |
| Vichy | 50 | 1,3 | 127/220 220/380 | |
| Vincennes | 50 | 1,3 | 127/220 220/380 | |
| All Others | 50 | 1,3 | 220/380 | |

Table B-1. Frequency and Single and Three-Phase Voltage Levels by Country—Continued

| Country/City | Frequency (Hz) | Number of Phases | Low Voltage (V) | Medium Voltage (kV) |
|---------------|----------------|------------------|--------------------|----------------------------|
| French Guiana | 50 | 1,3 | 220/380 | NA |
| Gabon | 50 | 1,3 | 220/380 | 5.5, 20 |
| Gambia | 50 | 1,3 | 220/380 | 11, 33 |
| Germany | 50 | 1,3 | 220/380 | 3, 6, 10, 20, 30, 45, 60 |
| Ghana | 50 | 1,3 | 220/400 | 11, 33, 34.5 |
| Gibraltar | 50 | 1,3 | 240/415 | NA |
| Greece | 50 | 1,3 | 220/380 | 6.6, 15, 20, 22 |
| Greenland | 50 | 1,3 | 220/380 | NA |
| Grenada | 50 | 1,3 | 230/400 | NA |
| Guadeloupe | 50 | 1,3 | 220/380 | 20 |
| Guam | 60 | 1,3 | 110/220 120/208 | 4, 13.8 |
| Guatemala | 60 | 1,3 | 120/240 | 22, 34.5, 50 |
| Guinea | 50 | 1,3 | 220/380 | 5.5, 6.3, 15, 20, 30 |
| Guinea-Bissau | 50 | 1,3 | 220/380 | 6, 10, 20, 30 |
| Guyana | 50 | 1,3 | 110/220 | 2.3, 4, 11, 13.8 |
| Haiti | | | | 2.4, 4.2, 7.2, 12.5* |
| Cap Haitien | 60 | 1,3 | 120/208 | |
| Gonaives | 60 | 1,3 | 120/208 | |
| All Others | 50 | 1,3 | 110/220 | |
| Honduras | 60 | 1,3 | 110/220 | 2.4, 4.2, 13.8, 34.5, 69 |
| Hong Kong | 50 | 1,3 | 200/346 | 11, 33 |
| Hungary | 50 | 1,3 | 220/380 | 6, 10, 20, 22, 30, 35 |
| Iceland | 50 | 1,3 | 220/380 | 6, 11, 22, 33 |
| India | | | | 2.2, 3.3, 6.6, 11, 15, 11* |
| Bombay City | 50 | 1,3 | 230/400 230/460 | |
| Madras | 50 | 1,3 | 230/400 250/440 | |
| Mussoorie | 50 | 1,3 | 220/380 | |
| Naini Tal | 50 | 1,3 | 220/380 | 11 |
| New Delhi | 50 | 1,3 | 230/400 230/415 | |
| Patna | 50 | 1,3 | 220/380 | |
| Simla | 50 | 1,3 | 220/380 | |
| All Others | 50 | 1,3 | 230/400 | |
| Indonesia | | | | 3-20* |
| Jakarta | 50 | 1,3 | 220/380 | |
| All Others | 50 | 1,3 | 127/200 | |
| Iran | 50 | 1,3 | 220/380 | 11, 20, 33, 63, 66 |
| Iraq | 50 | 1,3 | 220/380 | 6.6, 11 |

Foreign Voltages and Frequency – E04-029

| Country/City | Frequency (Hz) | Number of Phases | Low Voltage (V) | Medium Voltage (kV) |
|--------------|----------------|------------------|--------------------|-----------------------------|
| Ireland | 50 | 1,3 | 220/380 | 5, 10, 20, 38 |
| Isle of Man | 50 | 1,3 | 240/415 | NA |
| Israel | 50 | 1,3 | 230/400 | 6.3, 12.6, 22, 33* |
| Jerusalem | 50 | 1,3 | 220/380 | |
| Italy | 50 | 1,3 | 127/220 220/380 | 3.6, 10, 15, 20, 30, 45, 66 |
| Ivory Coast | 50 | 1,3 | 220/380 | NA |
| Jamaica | 50 | 1,3 | 110/220 | 6.9, 13.8, 24 |
| Japan | | | | 3, 6, 6.6, 11, 20, 22, 60* |
| Chiba | 50 | 1,3 | 100/200 | |
| Hakodate | 50 | 1,3 | 100/200 | |
| Kawasaki | 50 | 1,3 | 100/200 | |
| Muroran | 50 | 1,3 | 100/200 | |
| Niigata | 50 | 1,3 | 100/200 | |
| Otaru | 50 | 1,3 | 100/200 | |
| Sapporo | 50 | 1,3 | 100/200 | |
| Sendai | 50 | 1,3 | 100/200 | |
| Tokyo | 50 | 1,3 | 100/200 | |
| Yokohama | 50 | 1,3 | 100/200 | |
| Yokosuka | 50 | 1,3 | 100/200 | |
| All Others | 60 | 1,3 | 100/200 | |
| Jordan | 50 | 1,3 | 220/380 | 6.6, 11, 33 |
| Kenya | 50 | 1,3 | 240/415 | 11, 33, 40, 66 |
| Korea | 60 | 1,3 | 110/220 | 22.9 |
| | 60 | 1,3 | 120/208 | |
| | 60 | 1,3 | 220/380 | |
| | 60 | 1 | 120/240 | |
| Kuwait | 50 | 1,3 | 240/415 | NA |
| Laos | 50 | 1,3 | 220/380 | 6.6, 22 |
| Lebanon | | | | 11, 15, 33* |
| Tripoli | 50 | 1,3 | 110/190 220/380 | |
| Zahleh | 50 | 1,3 | 220/380 | |
| All Other | 50 | 1,3 | 110/190 | |
| Lesotho | 50 | 1,3 | 120/240 120/208 | 11, 33 |
| Liberia | 60 | 1,3 | 120/240 120/208 | 7.2, 12.5 |
| Libya | | | | NA |
| Barce | 50 | 1,3 | 230/400 | |
| Benghazi | 50 | 1,3 | 230/400 | |
| Darnah | 50 | 1,3 | 230/400 | |
| Al Bayda | 50 | 1,3 | 230 | |
| Sebha | 50 | 1 | 230 | |
| Tubruq | 50 | 1,3 | 230/400 | |
| All Other | 50 | 1,3 | 127/220 | |
| Luxembourg | 50 | 1,3 | 120/208 220/380 | 5, 15, 20, 65 |

Table B-1. Frequency and Single and Three-Phase Voltage Levels by Country-Continued

| Country/City | Frequency (Hz) | Number of Phases | Low Voltage (V) | Medium Voltage (kV) |
|--------------------|----------------|------------------|--------------------|-----------------------------------|
| Macau | 50 | 1,3 | 220/380 | 11 |
| Macedonia | NA | NA | NA | 6.6, 10 |
| Madagascar | | | | 5, 20, 35* |
| Ambatolampy | 50 | 1,3 | 220/380 | |
| Ambatondrazaka | 50 | 1,3 | 220/380 | |
| Tulear | 50 | 1,3 | 220/380 | |
| All Others | 50 | 1,3 | 127/220 220/380 | |
| Majorco Island | 50 | 1,3 | 127/220 220/380 | NA |
| Malawi | 50 | 1,3 | 230/400 | 3.3, 11, 33, 66 |
| Malaysia | 50 | 1,3 | 240/415 | 6.6, 11, 22, 33 |
| Maldives | 50 | 1,3 | 230/400 | 11 |
| Mali, Republic of | 50 | 1,3 | 220/380 | 15, 30 |
| Malta | 50 | 1,3 | 240/415 | 6, 11 |
| Martinique | 50 | 1,3 | 220 | NA |
| Mauritius | 50 | 1,3 | 230/400 | 6.5, 22 |
| Mexico | 60 | 1,3 | 127/220 | 6.6, 13.2, 13.8, 23, 34.5, 44, 69 |
| Monaco | 50 | 1,3 | 127/220 220/380 | 10, 20 |
| Montserrat | 60 | 1,3 | 230/400 | NA |
| Morocco | | | | 5.5, 20, 22* |
| Agadir | 50 | 1,3 | 127/220 220/380 | |
| Beni-Mellal | 50 | 1,3 | 127/220 220/380 | |
| El-Hoceima | 50 | 1,3 | 220/380 | |
| Khemisset | 50 | 1,3 | 220/380 | |
| Khenifra | 50 | 1,3 | 220/380 | |
| Oued-Zem | 50 | 1,3 | 127/220 220/380 | |
| Sidi Kacem | 50 | 1,3 | 127/220 220/380 | |
| Sidi Slimane | 50 | 1,3 | 127/220 220/380 | |
| Souk-El-Arba Gharb | 50 | 1,3 | 127/220 220/380 | |
| All Others | 50 | 1,3 | 127/220 | |
| Mozambique | 50 | 1,3 | 220/380 | 6.6, 11, 22, 33 |
| Myanmar/Burma | 50 | 1,3 | 230/400 | 3.3, 6.6, 11, 33 |
| Nepal | 50 | 1,3 | 220/440 | 11, 33 |
| Netherlands | | | | 5.3, 6, 10, 12.5, 20, 25* |
| Amsterdam | 50 | 1,3 | 220/380 220 | |
| Delft | 50 | 1,3 | 220/380 220 | |
| All Others | 50 | 1,3 | 220/380 | |

Foreign Voltages and Frequency - E04-029

| Country/City | Frequency (Hz) | Number of Phases | Low Voltage (V) | Medium Voltage (kV) |
|----------------------|----------------|------------------|-----------------|---|
| Netherlands Antilles | | | | NA |
| Aruba: | | | | |
| Lago Colony | 60 | 1 | 115/230 | |
| Oranjestad | 60 | 1,3 | 127/220 | |
| San Nicolas | 60 | 1,3 | 127/220 | |
| Bonaire: | | | | |
| Kralendijk | 50 | 1,3 | 127/220 | |
| Curacaco: | | | | |
| Emmastad | 50 | 1,3 | 223/380 | |
| Willemstad | 50 | 1,3 | 127/220 | |
| St. Martin: | | | | |
| Philipsburg | 60 | 1,3 | 120/208 | |
| New Caledonia | 50 | 1,3 | 220/380 | NA |
| New Zealand | 50 | 1,3 | 230/400 | 11 |
| Nicaragua | 60 | 1,3 | 120/240 | 13.8, 24.9 |
| Niger | 50 | 1,3 | 220/380 | 5.5, 15, 20 |
| Nigeria | 50 | 1,3 | 230/415 | 11, 33 |
| Norway | 50 | 1,3 | 230 | NA |
| Okinawa | | | | NA |
| Military Facilities | 60 | 1 | 120/240 | |
| All Cities | 60 | 1 | 100/200 | |
| Oman | 50 | 1,3 | 240/415 | 11, 33 |
| Pakistan | | | | 11, 33 |
| Hyderabad | 50 | 1,3 | 220/380 | |
| Karachi | 50 | 1,3 | 220/380 | |
| All Others | 50 | 1,3 | 230/400 | |
| Panama | | | | 11, 12, 34.5* |
| Colon | 60 | 1,3 | 115/230 | |
| Panama City | 60 | 1,3 | 115/230 | |
| Puerto Armuelles | 60 | 1,3 | 126/208 | |
| All Others | 60 | 1,3 | 120/240 | |
| All Others | 60 | 1,3 | 110/220 | |
| Papua New Guinea | 50 | 1,3 | 240/415 | 11, 22 |
| Paraguay | 50 | 1,3 | 220/380 | 23 |
| Peru | | | | 5, 10, 20, 30* |
| Arequipa | 50 | 1,3 | 220 | |
| Talara | 60 | 1,3 | 110/220 | |
| All Others | 60 | 1,3 | 220 | |
| Philippines | | | | 2.4, 4.8, 6.24, 7.62, 13.2, 13.8, 34.5* |
| Manila | 60 | 1,3 | 115/230 | |
| All Others | 60 | 1,3 | 110/220 | |
| All Others | 60 | 1,3 | 110/220 | |
| Poland | 50 | 1,3 | 220/380 | 6, 15, 20, 30, 40, 60 |
| Portugal | 50 | 1,3 | 220/380 | 6, 10, 15, 30, 40, 60 |
| Puerto Rico | 60 | 1,3 | 120/240 | 4.16, 13.2 |
| Qatar | 50 | 1,3 | 240/415 | 11 |

Table B-1. Frequency and Single and Three-Phase Voltage Levels by Country—Continued

| Country/City | Frequency (Hz) | Number of Phases | Low Voltage (V) | Medium Voltage (kV) |
|----------------------|----------------|------------------|-----------------|---------------------|
| Romania | 50 | 1,3 | 220/380 | 6, 10, 20 |
| Russia | 50 | 1,3 | 220/380 | NA |
| Rwanda | 50 | 1,3 | 220/380 | 6.6, 15, 30 |
| St. Kitts and Nevis | 60 | 1,3 | 230/400 | NA |
| St. Lucia | 50 | 1,3 | 240/416 | 11 |
| San Marino | NA | NA | NA | 15 |
| St. Vincent | 50 | 1,3 | 230/400 | 6.3, 11, 33 |
| Saudi Arabia | | | | 13.8, 33, 34.5, 69* |
| Al Khobar | 60 | 1,3 | 127/220 | |
| Buraydah | 50 | 1,3 | 220/380 | |
| Dammam | 60 | 1,3 | 127/220 | |
| Hufuf | 50 | 1,3 | 230/400 | |
| Jiddah | 60 | 1,3 | 127/220 | |
| Mecca | 50 | 1,3 | 230/400 | |
| Medina | 60 | 1,3 | 127/220 | |
| Riyadh | 60 | 1,3 | 127/220 | |
| Taif | 50 | 1,3 | 230/400 | |
| Senegal | 50 | 1,3 | 127/20 | 5.5, 16.6, 30 |
| Serbia | 50 | 1,3 | 220/380 | 10, 20, 35 |
| Seychelles | 50 | 1,3 | 240 | 11 |
| Sierra Leone | 50 | 1,3 | 230/400 | 11 |
| Singapore | 50 | 1,3 | 230/400 | 6.6, 22 |
| Slova Republic | NA | NA | NA | 6, 10, 22, 35 |
| Slovenia | NA | NA | NA | 6.6, 10 |
| Somalia | | | | 3, 15* |
| Berbera | 50 | 1,3 | 230 | |
| Brava | 50 | 1,3 | 220/440 | |
| Chisimaio | 50 | 1,3 | 220 | |
| Hargeysa | 50 | 1,3 | 220 | |
| Marka | 50 | 1,3 | 120/220 | |
| Mogadishu | 50 | 1,3 | 220/380 | |
| South Africa/Namibia | | | | 6.6, 11, 22, 33* |
| Beaufort West | 50 | 1,3 | 230/400 | |
| Benoni | 50 | 1,3 | 230/400 | |
| Boksburg | 50 | 1,3 | 230/400 | |
| Cradock | 50 | 1,3 | 230/400 | |
| Germiston | 50 | 1,3 | 230/400 | |
| Grahaamstad | 50 | 1,3 | 250/430 | |
| Keetmanshoop | 50 | 1,3 | 230/400 | |
| King Williams | 50 | 1,3 | 220/380 | |
| Klerksdorp | 50 | 1,3 | 250/433 | |
| Kroonstad | 50 | 1,3 | 230/400 | |
| Paarl | 50 | 1,3 | 230/400 | |
| Port Elizabeth | 50 | 1,3 | 250/433 | |
| Pretoria | 50 | 1,3 | 240/415 | |
| Roodepoort | 50 | 1,3 | 230/400 | |

Foreign Voltages and Frequency - E04-029

| Country/City | Frequency (Hz) | Number of Phases | Low Voltage (V) | Medium Voltage (kV) |
|------------------------------|----------------|------------------|--------------------|------------------------------|
| South Africa/Namibia (cont.) | | | | |
| Somerset West | 50 | 1,3 | 230/400 | |
| Springs | 50 | 1,3 | 220/380 | |
| Stellenbosch | 50 | 3 | 230/400 | |
| Umtata | 50 | 1,3 | 220/380 | |
| Upington | 50 | 1,3 | 230/400 | |
| Virginia | 50 | 1,3 | 230/400 | |
| Vryheid | 50 | 1,3 | 230/400 | |
| Walvis Bay | 50 | 1,3 | 230/400 | |
| Wellington | 50 | 1,3 | 230/400 | |
| Worcester | 50 | 1,3 | 230/400 | |
| All Others | 50 | 1,3 | 220/380 | |
| Spain | 50 | 1,3 | 127/220 220/380 | 3, 6.6, 10, 11.6, 15, 20, 33 |
| Sri Lanka | 50 | 1,3 | 230/400 | 11, 33 |
| Sudan | 50 | 1,3 | 240/415 | 11, 33 |
| Suriname | 60 | 1,3 | 115/230 | 33 |
| Swaziland | 50 | 1,3 | 230/400 | 11, 33 |
| Sweden | 50 | 1,3 | 220/380 | 3, 6, 7, 10, 20, 30 |
| Switzerland | 50 | 1,3 | 220/380 | 1, 16, 50 |
| Syria | 50 | 1,3 | 220/380 | 20 |
| Tahiti | 60 | 1,3 | 127/220 | 4.8, 14.4, 20 |
| Taiwan | 60 | 1,3 | 110/220 | 2.3, 3.3, 5.9, 11.4, 22.8 |
| Tanzania | 50 | 1,3 | 230/400 | 11, 33 |
| Thailand | 50 | 1,3 | 220/380 | 3.5, 11, 12, 22, 24, 33 |
| Togo | | | | 5.5, 20, 33* |
| Lome | 50 | 1,3 | 127/220 220/380 | |
| All Others | 50 | 1,3 | 220/380 | |
| Tonga | 50 | 1,3 | 240/415 | 11 |
| Trinidad and Tobago | 60 | 1,3 | 115/230 230/400 | 6.6, 12 |
| Tunisia | | | | 10, 15, 30* |
| Ariana | 50 | 1,3 | 127/220 220/380 | |
| Bardo | 50 | 1,3 | 127/220 220/380 | |
| Beja | 50 | 1,3 | 127/220 | |
| Bizerte | 50 | 1,3 | 127/220 | |
| Carthage | 50 | 1,3 | 127/220 | |
| Gafsa | 50 | 1,3 | 127/220 220/380 | |
| Hammam-Lif | 50 | 1,3 | 127/220 | |
| Kairouan | 50 | 1,3 | 127/220 | |
| La Goulette | 50 | 1,3 | 127/220 | |
| La Manouba | 50 | 1,3 | 127/220 | |
| La Marsa | 50 | 1,3 | 127/220 | |
| Mateur | 50 | 1,3 | 127/220 | |

Foreign Voltages and Frequency - E04-029

Table B-1. Frequency and Single and Three-Phase Voltage Levels by Country--Continued

| Country/City | Frequency (Hz) | Number of Phases | Low Voltage (V) | Medium Voltage (kV) |
|--------------------------|----------------|------------------|--------------------|--|
| Tunisia (continued) | | | | |
| Menzel Bourguiba | 50 | 1,3 | 127/220 | |
| Sfax | 50 | 1,3 | 127/220 220/380 | |
| Sousse | 50 | 1,3 | 127/220 | |
| Tunis | 50 | 1,3 | 127/220 220/380 | |
| All Others | 50 | 1,3 | 220/380 | |
| Turkey | | | | 6.3, 10.5, 15, 34.5* |
| Istanbul | 50 | 1,3 | 110/220 220/380 | |
| All Others | 50 | 1,3 | 220/380 | |
| Uganda | 50 | 1,3 | 240/415 | 11, 33 |
| United Arab Emirates | | | | 6.6, 11, 33* |
| Abu Dhabi | 50 | 1,3 | 240/415 | |
| Ajman | 50 | 1,3 | 230/400 | |
| Dubai | 50 | 1,3 | 220/380 | |
| United Kingdom: | | | | |
| England | 50 | 1,3 | 240/480 240/415 | 3.5, 6.6, 11, 22, 33, 66 |
| Scotland | 50 | 1,3 | 240/415 | 6.6, 11, 22, 33 |
| Northern Ireland | 50 | 1,3 | 220/380 230/400 | 6.6, 11, 33 |
| United States of America | 60 | 1,3 | 120/240 120/208 | 2.4, 4.16, 4.8, 6.9, 8.32, 12, 12.47, 13.2, 13.8, 14.4, 19.9, 20.8, 22.86, 23, 24.94, 34.5, 46, 69 |
| Upper Volta | 50 | 1,3 | 220/380 | NA |
| Uruguay | 50 | 1,3 | 220 | 6, 15, 30, 60 |
| Venezuela | 60 | 1,3 | 120/240 | 2.4, 4.16, 4.8, 12.47, 13.8 |
| Vietnam | | | | 6.6 (south) 10 (north) 15 (middle) 35 (entire) |
| Ban Me Thout | 50 | 1,3 | 220/380 | |
| Can Tho | 50 | 1,3 | 127/220 220/380 | |
| Dalat | 50 | 1,3 | 120/208 220/380 | |
| Da Nang | 50 | 1,3 | 127/220 | |
| Hue | 50 | 1,3 | 127/220 | |
| Khanh Hung | 50 | 1,3 | 220/380 | |
| Saigon | 50 | 1,3 | 120/208 220/380 | |
| | | | | Note: State has plans to change to 22 kV for whole country. |
| Virgin Islands | 60 | 1,3 | 120/240 | NA |
| Western Samoa | 50 | 1,3 | 230/400 | 6.6, 22 |
| Yemen | 50 | 1,3 | 250/440 | NA |
| Zaire | 50 | 1,3 | 220/380 | 6.6, 15, 20, 30 |
| Zambia | 50 | 1,3 | 220/380 | 11, 33, 66 |
| Zimbabwe | | | | 11, 22, 33, 66* |
| Bulawayo | 50 | 1,3 | 230/400 | |
| All Others | 50 | 1,3 | 220/380 | |

APPENDIX C

Derating Factors

C-1. Heating, ventilation, and air conditioning (HVAC).

a. 50 Hz. The output of directly coupled, motor driven equipment must be derated to account for the reduction in shaft speed to 5/6 the 60 Hz value. Otherwise, the mechanical coupling used between the motor and driven equipment should be purchased to give the required rotating speed. HVAC controls that are frequency dependent must be purchased in 50 Hz configurations.

b. Voltage. Derating for voltage is not an option.

C-2. Electrical distribution and protection for transformers.

a. 50 Hz. In general, derating for frequency is not recommended. See chapter 3 for details.

b. Voltage. Derating for voltage is not recommended. Vendors can provide almost any needed input voltage rating. Consult vendor regarding derating possibility if derating is absolutely necessary.

C-3. Electrical distribution and protection for power factor capacitors.

a. 50 Hz. Derate kilovolt-amperes reactive (KVAR) rating by multiplying 60 Hz KVAR rating by 5/6 to yield 50 Hz KVAR rating.

b. Voltage. Derating for voltage is not recommended. Vendors can provide almost any needed voltage rating. Consult vendor regarding derating possibility if derating is absolutely necessary.

C-4. Electrical distribution and protection for protection equipment.

a. 50 Hz. Different trip curves may be needed. Consult vendor for these curves.

b. Voltage. Derating for voltage should not be needed. Verify with vendor since special protection equipment may need derating.

C-5. Other electrical distribution and protection.

Derating either cannot or should not be performed. Contact vendors to purchase appropriately rated equipment.

C-6. Safety and security equipment.

a. 50 Hz. Depends on type of power supply. Derating is either not necessary or not possible. Contract vendor to purchase appropriately configured power supply.

b. Voltage. Derating for voltage is not recommended. Contact vendor to purchase appropriately configured power supply, or use transformer to convert supply voltage level to power supply input level.

C-7. Communication equipment.

a. 50 Hz. Depends on type of power supply. Derating is either not necessary or not possible. Contact vendor to purchase appropriately configured power supply.

b. Voltage. Derating for voltage is not recommended. Contact vendor to purchase appropriately configured power supply, or use transformer to convert supply voltage level to power supply input level.

C-8. Incandescent lighting.

a. 50 Hz. No derating necessary. Incandescents are frequency insensitive.

b. Voltage. Not possible. Bulb life will suffer drastically. Contact vendor to purchase high voltage bulbs, or use transformer to convert supply voltage to lamp voltage.

C-9. Fluorescent and high intensity discharge (HID) lighting.

50 Hz. Derating is not recommended. Fixtures configured for 50 Hz should be purchased.

C-10. Motors.

a. 50 Hz. In general, derating a 60 Hz motor is not recommended. See chapter 3 for exceptions

b. Voltage. Derating for voltage is not recommended. Contact vendor to purchase appropriately configured equipment, or use transformer to convert supply voltage to motor's rated voltage level.

C-11. Motor Starters.

a. 50 Hz. Derate by multiplying 60 Hz horsepower rating by 4/5 to yield the 50 Hz horsepower rating.

b. Voltage. Derating for voltage is not possible. Contact vendor to purchase appropriately configured equipment, or use transformer to convert supply voltage to motor starter's rated voltage level.

C-12. Clocks.

a. 50 Hz. Derating is possible but meaningless since 60 Hz clock will not keep correct time in 50 Hz environment

b. Voltage. Derating for voltage is not recommended. Contact vendor to purchase appropriately configured clocks, or use transformer to convert supply voltage to clock's rated voltage level.

C-13. Computer power supplies.

a. 50 Hz. Derating is not possible due to equipment construction. Contact vendor to purchase 50 Hz rated equipment.


b. Voltage. Derating for voltage is not possible. Contact vendor to purchase appropriately configured equipment, or use transformer to convert supply voltage to equipment's rated voltage level.

The proponent agency of this publication is the Chief of Engineers, United States Army. Users are invited to send comments and suggested improvements on DA Form 2028 (Recommended Changes to Publications and Blank Forms) directly to HQUSACE, (ATTN: CEMP-SP), Washington, DC 20314-1000.

By Order of the Secretary of the Army:

ERIC K. SHINSEKI
General, United States Army
Chief of Staff

Official



JOEL B. HUDSON
Administrative Assistant to the
Secretary of the Army

Distribution:

To be distributed in accordance with initial Distribution Number (IDN), 344698, requirements for TM 5-688.